



TO: Leonard Ementary
RE: 335 E Elmwood; Leonard
WSSN: 2057463
PURPOSE: Routine

DATE: December 5, 2023
SAMPLE #: 65794
COLLECTED BY: Geoff Todd

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	R/L	Testing Method
1. Total Coliform Bacteria	Not Detected	11/29/23	2:09p	Kir 3-C Sink	11/29/23	4:04p	AK	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	11/29/23	2:09p	Kir 3-C Sink	11/29/23	4:04p	AK	0	1 cfu/100ml	9223B
3. Arsenic	Not Detected	11/29/23	2:03p	POE Treated Tap	12/1/23	10:59a	VC	10 ppb	2 ppb	SM 3113B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.