



LABORATORIES, INC.

COMPLETE WATER TESTING SERVICES  
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Clear Lake Elem

RE: 2085 W Drahner

WSSN: 21413-63

PURPOSE: Routine

DATE: March 4, 2022

SAMPLE NO: 53808

COLLECTED BY: AT - Geoff Todd

## ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Total Coliform Bacteria	Not Detected	3/2/22	1:34p	3 Comp Sink- Kit	3/2/22	3:53p	TP	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	3/2/22	1:34p	3 Comp Sink- Kit	3/2/22	3:53p	TP	0	1 cfu/100ml	9223B
3. Nitrates	Not Detected	3/2/22	1:41p	Sample Tap	3/3/22	9:53a	TP	10 ppm	1 ppm	Hach10206
4. Nitrites	Not Detected	3/2/22	1:41p	Sample Tap	3/3/22	9:53a	TP	1 ppm	0.10 ppm	4500-NO <sub>2</sub> -B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.

This report is for the use of the above addressed person and is for informational purposes only.

EPA LABORATORY #MI 01189 MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY LABORATORY #9975

22-53808 Mar Bact Nit Clear Lk Elem

9165 HIGHLAND ROAD, WHITE LAKE, MI 248-698-9500 info@aquatestlabs.com