



TO: Clear Lake Elem
RE: 2085 W Drahner
WSSN: 21413-63
PURPOSE: Routine

DATE: September 9, 2022
SAMPLE NO: 59178
COLLECTED BY: AT - Geoff Todd

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Total Coliform Bacteria	Not Detected	9/7/22	10:27a	Kit 3 Comp Sink	9/7/22	4:54p	VC	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	9/7/22	10:27a	Kit 3 Comp Sink	9/7/22	4:54p	VC	0	1 cfu/100ml	9223B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.
This report is for the use of the above addressed person and is for informational purposes only.