



LABORATORIES, Inc.
COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Leonard Elementary
RE: 335 E. Elmwood
WSSN: 20574-63
PURPOSE: Routine

DATE: June 10, 2019
SAMPLE NO: 35528
COLLECTED BY: AquaTest - GT

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled	Sample Location	Date/Time Analyzed	Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Arsenic	3.5 ppb	6/4/19 7:08a	Treated Tap	6/6/19 5:18p	VC	10 ppb	2 ppb	SM 3113B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.



LABORATORIES, Inc.
COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Leonard Elementary
RE: 335 E. Elmwood
WSSN: 20574-63
PURPOSE: Routine

DATE: June 10, 2019
SAMPLE NO: 35528
COLLECTED BY: AquaTest - GT
RECEIVED: Acceptable

ANALYTICAL REPORT

PARAMETER	Result (ppb)	Date/Time Sampled	Fixture Location- Fixture Type	Date/Time Analyzed	Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Copper	Not Detected	6/4/19 7:01 AM	Kitchen	6/9/19 12:37 PM	VC	1300 ppb	10 ppb	SM 3113B
1. Lead	Not Detected	6/4/19 7:01 AM	3 Comp Sink	6/9/19 8:34 AM	VC	15 ppb	1.0 ppb	SM 3113B
2. Copper	Not Detected	6/4/19 6:57 AM	Staff Lounge	6/9/19 12:37 PM	VC	1300 ppb	10 ppb	SM 3113B
2. Lead	Not Detected	6/4/19 6:57 AM	Break Sink	6/9/19 8:34 AM	VC	15 ppb	1.0 ppb	SM 3113B
3. Copper	12.6	6/4/19 6:48 AM	Rm 16 - Lower	6/9/19 12:37 PM	VC	1300 ppb	10 ppb	SM 3113B
3. Lead	Not Detected	6/4/19 6:48 AM	Drinking Frtn	6/9/19 8:34 AM	VC	15 ppb	1.0 ppb	SM 3113B
4. Copper	Not Detected	6/4/19 6:52 AM	Hall Rm 25 - Upper	6/9/19 12:37 PM	VC	1300 ppb	10 ppb	SM 3113B
4. Lead	Not Detected	6/4/19 6:52 AM	Drinking Frtn	6/9/19 8:34 AM	VC	15 ppb	1.0 ppb	SM 3113B
5. Copper	Not Detected	6/4/19 6:54 AM	Hall Rm 25 - Lower	6/9/19 12:37 PM	VC	1300 ppb	10 ppb	SM 3113B
5. Lead	Not Detected	6/4/19 6:54 AM	Drinking Frtn	6/9/19 8:34 AM	VC	15 ppb	1.0 ppb	SM 3113B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.

19-35528 June LC Leonard EI

EPA LABORATORY #MI 01189 MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY LABORATORY #9975
9165 HIGHLAND ROAD, WHITE LAKE, MI 248-698-9500 info@aquatestlabs.com